

The Low Voltage Directive (LVD) 2006/95/EC, Electromagnetic Compatibility (EMC) Directive 2004/108/EC and Directive 94/9/EC on equipment and protective systems intended for use in potentially explosive atmospheres (ATEX).

### a) The manufacturer

Dinel, s.r.o.  
U Tescomy 249  
760 01 Zlín, Czech Republic

ID: 63476886  
VAT: CZ63476886  
web: www.dinel.cz

Tel.: +420 577 002 001  
Fax: +420 577 002 007  
E-mail: dinel@dinel.cz

### b) The Products Covered by this Declaration

#### Capacitive level transducer

DLS-27Xi (XiT, XiM, XiMT)

### c) Product brief

The capacitive level transducer type DLS-27 is designed to bistable level indication in tanks or containers. It allows level sensing and indication of electric conductive and non-conductive liquids, bulky materials, granulate and grain.

### d) The Basis on which Conformity is being Declared

Intrinsic safety: EN 60079-0:2009  
EN 60079-11:2012  
EN 60079-26:2007

Electromagnetic compatibility: EN 55022-class B  
EN 61326-1  
EN 61000-4-2  
EN 61000-4-3  
EN 61000-4-4  
EN 61000-4-5  
EN 61000-4-6

### e) Details of accredited person

Intrinsic safety: Notified Body No. NB 1026, FTZÚ (Physical-Technical Testing Institute), Pikartská 7, 716 07 Ostrava-Radvanice, Czech Republic, ID: 00577880.  
EC-Type Examination Certificate No. FTZÚ 02 ATEX 0234X from 8.10.2002, Supplement No. 1 from 9.2.2004, supplement No. 2 from 15.8.2007 and supplement No. 3 from 15.8.2012.

Electromagnetic compatibility: Accredited testing laboratory No. 1032, Mesit QM, spol. s.r.o., Sokolovská 573, 686 01 Uherské Hradiště, Czech Republic, ID: 47910381.  
EMC protocol No. 3665/0 from 11.12.2000.

### f) Special conditions for safe use

II 1G Ex ia IIB T6 Ga, II 1D Ex ia IIIC T76°C Da, II 1/2G Ex ia IIB T6 Ga/Gb, II 1/2D Ex ia IIIC T76°C Da/Db, I M2 Ex ia I Mb.  
If the apparatus is used as device of Group II and with using of an approved power supply device, which output parameters comply with required input parameters, it is necessary to have a galvanic separation or in case of apparatus without galvanic separation (Zener barriers) it is necessary to provide equipotential equalizing between sensor and barrier earthing point.

If the apparatus is used in coal mine as device of Group I and with using of an approved power supply device, which output parameters comply with required input parameters it is necessary to have a galvanic separation.

When used in zone 0 the present explosive atmosphere of air mixture and gases, vapours of mists must be comply with:  
 $20^{\circ}\text{C} \leq T_{\text{amb}} \leq 60^{\circ}\text{C}$ ;  $0.8 \text{ bar} \leq p \leq 1.1 \text{ bar}$ .

Design DLS-27Xi can be used in zone 0 or zone 20. With design DLS-27XiT can be used in zone 0 and zone 20 only electrode part head with electronics can be used only in zone 1 or zone 21.

Ambient temperature:  $T_{\text{amb}} = -20^{\circ}\text{C}$  to  $+75^{\circ}\text{C}$

Temperature of measured medium according to design variant: Xi, XiM:  $(-20^{\circ}\text{C}$  to  $+85^{\circ}\text{C})$   
XiT, XiMT: for types 10, 11, 20, 30  $(-30^{\circ}\text{C}$  to  $+200^{\circ}\text{C})$   
XiT, XiMT: for types 21, 22, 31, 40  $(-30^{\circ}\text{C}$  to  $+120^{\circ}\text{C})$

Maximum temperature of electrodes is equal to temperature of measured medium. For design DLS–27XiMT it is necessary to observe that temperature of any surface of apparatus, when coal dust can from a layer, do not exceed 150°C.

Maximum input parameters:

$U_i = 12 \text{ V}$ ;  $I_i = 15 \text{ mA}$ ;  $P_i = 45 \text{ mW}$ ;  $C_i = 15 \text{ nF}$ ;  $L_i = 10 \text{ }\mu\text{H}$

#### **g) Ensure production quality**

Manufacturer's quality management system was found conform with the requirements of ISO 9001: 2008. The company is holder of the certificate of quality management system, reg. number CZ – 2256/2012 dated 13.10.2015 and valid until 15.9.2018, issued by certification body CQS (IQNet). The certificate is valid for the development, manufacture and sales of electronic components and systems for measurement, control and industrial automation.

For products in potentially explosive atmospheres are to quality management system according to ISO 9001 applied special requirements according to EN 13980:2004. The manufacturer got QUALITY ASSURANCE NOTIFICATION No. "FTZÚ 02 ATEX Q 016", issued by the Notified Body NB 1026 FTZÚ Ostrava-Radvanice. The notification is issued for protective systems intended for use in potentially explosive atmospheres acc. to Directive 94/9/EC. The notice applies to a group of products with the type of explosion protection – Intrinsic safety "i" Protection with enclosure "t" and was issued on the basis of the audit protocol No. FTZÚ 02/ATEX/016 issued on 12.06.2014 and valid until 30.06.2017.

#### **h) Manufacturer confirmation**

The manufacturer identified in paragraph a) of this statement confirms that the properties of the product identified in point b) and c) of this declaration, meet the requirements, concretized in European technical standards identified in paragraph d) of this statement.

The product is under manufacturer's intended use safe. The manufacturer confirms that he has taken actions to ensure conformity of all products put on the market with technical documentation and the basic requirements.

Issued in Zlín, on 11.1.2016



Ing. Dalibor Štverka, Ph.D.  
*General manager*