

The Low Voltage Directive (LVD) 2014/35/EU, Electromagnetic Compatibility (EMC) Directive 2014/30/EU, Directive 2014/34/EU on equipment and protective systems intended for use in potentially explosive atmospheres (ATEX) and Directive (RoHS) 2011/65/EU ((EU) 2015/863, (EU) 2017/2102) on the restriction of the use of certain hazardous substances in electrical and electronic equipment.

a) The manufacturer

Dinel, s.r.o.
U Tescomy 249
760 01 Zlín, Czech Republic

ID: 63476886
VAT: CZ63476886
web: www.dinel.cz

Tel.: +420 577 002 001
E-mail: dinel@dinel.cz

b) The Products Covered by this Declaration

High Frequency Limit Level Sensor

RFLS-35Xi(XiM)

c) Product brief

High Frequency Limit Level Sensor type RFLS-35Xi(XiM) is designed to limit sensing of level of liquid and paste mediums.

d) The Basis on which Conformity is being Declared

Intrinsic safety:	EN IEC 60079-0:2018 EN 60079-11:2012 EN 50303:2000
Electromagnetic compatibility:	EN 61326-1 2013 EN 55011 2009 - class B EN 61000-4-2 2009 Criterion A EN 61000-4-3 2006 + A1:2007 + A2:2010 Criterion A EN 61000-4-4 2012 Criterion B EN 61000-4-5 2006 Criterion B EN 61000-4-6 2006 Criterion A EN 61000-4-8 2010 Criterion A

e) Details of accredited person

Intrinsic safety:	Notified Body No. NB 1026, FTZÚ (Physical-Technical Testing Institute), Pikartská 1337/7, 716 07 Ostrava-Radvanice, Czech Republic. EC-Type Examination Certificate No. FTZÚ 16 ATEX 0139X from 16. 03. 2017 and Supplement No. 1 from 27. 11. 2020.
Electromagnetic compatibility:	Accredited testing laboratory No. 1004.3, Institute for testing and certification, a.s., Sokolovská 573, 686 01 Uherské Hradiště, Czech Republic, ID: 47910381. EMC protocol No. 414103027AE1 from 18. 12. 2015.

f) Special conditions for safe use

Version RFLS-35Xi:	 II 1G Ex ia IIB T5 Ga
Version RFLS-35XiM:	 I M1 Ex ia I Ma

Connected intrinsically safe apparatus must be galvanically separated or in the case of using the apparatus without galvanic separation (Zener barrier) it is necessary to carry out the equalization of potentials between transducer and the palce of barriers. The version RFLS-35Xi can be placed into Zone 0. For the implementation RFLS-35XiM must be observed that the temperature of any surface, where coal dust can form a layer, does not exceed 100°C.

Intrinsically safe parameters:

Ui = 12 VDC, Ii = 15 mA, Pi=45 mW, Li = 10 µH, Ci = 15 nF

Ambient temperature:

-40°C ≤ Ta ≤ + 80°C

g) Ensure production quality

The manufacturer's quality management system was found to comply with the requirements of EN ISO 9001:2016. The company holds the quality management system certificate, reg. number CQS 2191/2024, dated October 13, 2024, and valid until October 12, 2027, issued by the certification body CQS (IQNet). The certificate is valid for the development, manufacture, and sale of electronic components and systems for measurement, control, and industrial automation.

For products in potentially explosive atmospheres are to quality management system according to ISO 9001 applied special requirements according to EN ISO/IEC 80079-34:2020. The manufacturer got QUALITY ASSURANCE NOTIFICATION No. "FTZÚ 02 ATEX Q 016", issued by the Notified Body NB 1026 FTZÚ Ostrava-Radvanice. The notification is issued for protective systems intended for use in potentially explosive atmospheres acc. to Directive 2014/34/EU. The notice applies to a group of products with the type of explosion protection – Intrinsic safety "i" Protection with enclosure "t" and was issued on the basis of the audit protocol No. FTZÚ 02/ATEXQ/016 issued on 16. 6. 2023 and valid until 30. 6. 2026.

h) Manufacturer confirmation

The manufacturer identified in paragraph a) of this statement confirms that the properties of the product identified in point b) and c) of this declaration, meet the requirements, concretized in European technical standards identified in paragraph d) of this statement.

The product is under manufacturer's intended use safe. The manufacturer confirms that he has taken actions to ensure conformity of all products put on the market with technical documentation and the basic requirements.

Issued in Zlín, on March 1, 2025



Ing. Dalibor Štverka, Ph.D.
General manager