

Electromagnetic Compatibility (EMC) Directive 2014/30/EU, Directive 2014/34/EU on equipment and protective systems intended for use in potentially explosive atmospheres (ATEX) and Directive (RoHS) 2011/65/EU on the restriction of the use of certain hazardous substances in electrical and electronic equipment.

a) The manufacturer

Dinel, s.r.o.
U Tescomy 249
760 01 Zlín, Czech Republic

ID: 63476886
VAT: CZ63476886
web: www.dinel.cz

Tel.: +420 577 002 001
E-mail: dinel@dinel.cz

b) The Products Covered by this Declaration

Ultrasonic level meter

ULM-70Xi-__-I

c) Product brief

Ultrasonic level meter ULM-70Xi-__-I is intended to continuous non-contact level measurement of liquids and bulk-solid materials.

d) The Basis on which Conformity is being Declared

Intrinsic safety: EN IEC 60079-0:2018
EN 60079-11:2012




Electromagnetic compatibility: EN 55011-class B
EN 61326-1 industrial areas
EN 61000-4-2 Criterion A
EN 61000-4-3 Criterion A
EN 61000-4-4 Criterion B
EN 61000-4-5 Criterion A
EN 61000-4-6 Criterion A

e) Details of accredited person

Intrinsic safety:
Notified Body No. NB 1026, FTZÚ (Physical-Technical Testing Institute), Pikartská 1337/7,
716 07 Ostrava-Radvanice, Czech Republic.
EC-Type Examination Certificate No. FTZÚ 09 ATEX 0277X from 11. 1. 2010, Supplement No. 1 from 13. 3. 2015 and
Supplement No. 2 from 19. 6. 2020.

Electromagnetic compatibility:
Accredited testing laboratory No. 1004.3, Institute for testing and certification, a.s., Sokolovská 573,
686 01 Uherské Hradiště, Czech Republic, ID: 47910381.
EMC protocol No. 3684/09 from 21. 9. 2009.

f) Special conditions for safe use

   The device is designed for connection to the isolating repeater IRU-420. When the other approved supply unit is used, whose output parameters satisfy above mentioned output parameters, it is necessary to have a galvanic separation or, if supply unit without galvanic separation is used (Zener barriers), it is necessary provide potential equalization between sensor and point of barrier earthing.

For application in zone 0 the present explosive atmospheres - mixture of air with flammable gases, vapour or mists must comply: 0.8 bar < p < 1.1 bar. The device must be installed in such a way, to prevent mechanical damage of sensor face. It is necessary carried out earthing by screw which is placed on head of level meter.

Maximum input parameters:
 $U_i = 30 \text{ V}$; $I_i = 132 \text{ mA}$; $P_i = 0.99 \text{ W}$; $C_i = 370 \text{ nF}$; $L_i = 0.9 \text{ mH}$

g) Ensure production quality

Manufacturer's quality management system was found conform with the requirements of EN ISO 9001: 2016. The company is holder of the certificate of quality management system, reg. number CQS 2201/2021 dated 13.10.2021 and valid until 12. 10. 2024, issued by certification body CQS (IQNet). The certificate is valid for the development, manufacture and sales of electronic components and systems for measurement, control and industrial automation.

For products in potentially explosive atmospheres are to quality management system according to ISO 9001 applied special requirements according to EN ISO/IEC 80079-34:2020. The manufacturer got QUALITY ASSURANCE NOTIFICATION No. "FTZÚ 02 ATEX Q 016", issued by the Notified Body NB 1026 FTZÚ Ostrava-Radvanice. The notification is issued for protective systems intended for use in potentially explosive atmospheres acc. to Directive 2014/34/EU. The notice applies to a group of products with the type of explosion protection – Intrinsic safety "i" Protection with enclosure "t" and was issued on the basis of the audit protocol No. FTZÚ 02/ATEXQ/016 issued on 16. 6. 2023 and valid until 30. 6. 2026.

h) Manufacturer confirmation

The manufacturer identified in paragraph a) of this statement confirms that the properties of the product identified in point b) and c) of this declaration, meet the requirements, concretized in European technical standards identified in paragraph d) of this statement.

The product is under manufacturer's intended use safe. The manufacturer confirms that he has taken actions to ensure conformity of all products put on the market with technical documentation and the basic requirements.

Issued in Zlín, on 24. 7. 2023



Ing. Dalibor Štverka, Ph.D.
General manager